


NOTES:

- 1) Exterior Colour to be Industrial Grey.
- 2) Est. Total Empty Weight = 175 lbs.
- 3) Actual Capacity = 204 Imp. Gallons
- 4) Move Tank Only by the Lifting Handles Provided. Do Not Use Chains or Cables Around Tank.
- 5) Store Tank in a Vertical Position. Do Not Rest Against Sharp Objects.
- 6) Six Legs are Available (REF. dwg. A9911-003)
- 7) Burner Supply and/or bottom fitting may be a 1/2" or 2" FNPT half coupling.



| No. | Description | Date | By |
|-----|-------------------------------|-----------|----|
| 6 | modified fitting to 1 1/2" | May 24/91 | BB |
| 5 | modified burner fit to 1/2" | Dec 03/91 | LB |
| 4 | removed ground leg | Oct 09/91 | LB |
| 3 | middle location, triple plate | Aug 28/91 | LB |
| 2 | Modified nomenclature | 11/04/91 | LB |
| 1 | Added Ground Piece | 11/17/90 | BB |
| 0 | Per Customer Info Only | 04/28/90 | BB |


Revision or Issue

TITLE:
FRP FUEL OIL TANK - FRP CRADLE
200 IMP. GAL. NOMINAL CAPACITY
SINGLE WALL TANK


ZCL PHONE: 1-800-661-8285
 COMPOSITES INC. FAX: 1-780-466-6126

Scale: 1" = 1'

| Date | Design | Checked | Approved |
|----------------|--------------|---------|--------------|
| Nov. 20, 1999 | F.J.L. | B.S. | F.J.L. |
| Work Order No. | ----- | | Sheet of 1/1 |
| Drawing No. | C9911-003-03 | | Revision 0 |



- NOTES:**
- 1) Exterior Colour to be Industrial Grey.
 - 2) Est. Total Empty Weight - 195 lbs.
 - 3) Actual Capacity - 204 Imp. Gallons
 - 4) Move Tank Only by the Lifting Handles Provided. Do Not Use Chains or Cables Around Tank.
 - 5) Store Tank in a Vertical Position. Do Not Rest Against Sharp Objects.
 - 6) Still Legs are Available (REF. dwg. A9911-003)
 - 7) Burner Supply and/or bottom fitting may be a 1/2" or 2" FNPT half coupling.



| | | | |
|---|-------------------------------|-----------|----|
| 6 | modified fitting to 1 1/2" | May 24/92 | BB |
| 5 | modified burner fit to 1/2" | Dec 05/90 | LL |
| 4 | removed ground lag | Oct 02/91 | LJ |
| 3 | middle location, triple plate | Aug 28/91 | LJ |
| 2 | modified terminology | 11/04/91 | LL |
| 1 | Added Ground Plate | 11/17/90 | BB |
| 0 | For Customer Info Only | 06/28/90 | BB |


Revision or Issue

TITLE:
FRP FUEL OIL TANK - FRP CRADLE
200 IMP. GAL. NOMINAL CAPACITY
DOUBLE WALL TANK
SIGHT GLASS MONITORING

ZCL PHONE: 1-800-681-8285
 COMPOSITES INC. FAX: 1-780-486-8128


Scale: 1" = 1"

| | | | |
|-------------|---------------|----------------|-----|
| Date | Nov. 20, 1999 | Drawn | BB |
| Designed | F.J.L. | Checked | BB |
| Approved | F.J.L. | Work Order No. | --- |
| Drawing No. | C9912-003-03 | Revision | 0 |



NOTES:

- 1) Exterior Colour to be Industrial Grey.
- 2) Est. Total Empty Weight = 215 lbs.
- 3) Actual Capacity = 254 Imp. Gallons
- 4) Move Tank Only by the Lifting Handles Provided.
Do Not Use Chains or Cables Around Tank.
- 5) Store Tank in a Vertical Position. Do Not Rest Against Sharp Objects.
- 6) Stil Legs are Available (REF dwg. A9911-003)
- 7) Burner Supply and/or bottom fitting may be a 1/2" or 2" FNPT half coupling.



| No. | Description | Date | By |
|-----|-------------------------------|-----------|----|
| 6 | modified fitting to 1 1/2" | May 24/02 | BB |
| 5 | modified burner fit to 1/2" | Dec 05/00 | LJ |
| 4 | removed ground lag | Oct 06/01 | LJ |
| 3 | middle location, triple plate | Aug 28/01 | LJ |
| 2 | Mod End terminology | 11/04/01 | LJ |
| 1 | Added Ground Plate | 11/17/00 | BB |
| 0 | For Customer Info Only | 04/28/98 | BB |

Revision or Issue

TITLE:
FRP FUEL OIL TANK - FRP CRADLE
250 IMP. GAL. NOMINAL CAPACITY
DOUBLE WALL TANK
SIGHT GLASS MONITORING

ZCL PHONE: 1-800-881-8285
COMPOSITES INC. FAX: 1-780-486-8128

Scale:
1" = 1'

| Date | Drawn |
|-----------------------------|-----------------|
| Nov. 20, 1999 | BB |
| Designed FJL | Checked BB |
| Approved FJL | |
| Work Order No. ----- | Sheet of 1/1 |
| Drawing No. C9912-004-03 | Revision 0 |